

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7315-1335:107 Page 1 of 1

**CATEGORY:** Power Units

**LISTEE:** Altronix Corp., 140 - 58th Street, Building A-3W, Brooklyn NY 11220  
Contact: Alan Forman (718) 567-8181 Fax (718) 567-9056

**DESIGN:** Models AL800UL-ADA and AL802UL-ADA Indicating Circuit Power Supply. Unit is a regulated 12 or 24 VDC power supply/charger used for supervision and expanded power driving capability of up to four notification appliance circuits. The unit is intended for use with Altronix's Model EOL22 end-of-line resistor package. Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:** 120 VAC input, 12 or 24 VDC output

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction

**MARKING:** Listee's name, model number, electrical rating and UL label.

**APPROVAL:** Listed as power supply units for use with separately listed compatible fire alarm control units. Authority having jurisdiction should be consulted prior to installation. \*Model AL802UL-ADA is capable of providing synchronization out of Gentex, Faraday, System Sensor and AMSECO appliances.

**NOTE:** For fire alarm use, the standby batteries must provide at least 24 hours standby power during power loss. The battery circuit must be fully supervised.

\*Rev. 07-16-01



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 22, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy  
Program Manager**